

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Pinedale Estates DWID Has Levels of Selenium Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. On 1/26/2023, we received notice that the sample collected on 1/11/2023 showed that our system exceeds the standard, or maximum contaminant level (MCL), for Selenium. The standard for Selenium is 0.05 Mg/L. The average level of Selenium over the last year has been 0.33.

What should I do?

- There is nothing you need to do. **You do not need to** boil your **water** or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. However, If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What is being done?

Join PEDWID Saturday May 27th at Pinedale - Clay Springs Fire Station. There will be an ice cream social, hamburgers, hot dogs, and ice cream sundays provided from 11:30AM - 1:00PM. Members of the board and the system operator will be available to answer any questions. Following the ice cream social will be a board meeting and presentation to update the community on the status of the project. We are actively pursuing acquisition of a new well site. We anticipate resolving the problem within 12 - 18 months.

For more information, please contact Michael Eckert at 505-331-3709 or smeckert@q.com.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by PEDWID. State Water System ID#: AZ0409040.

Date distributed:4/20/21