




# Pinedale Estates DWID

Board of Directors Meeting

Pinedale Fire Station

December 13, 2019

# Source Water Protection




Pinedale Estates DWID  
Public Water System #AZ0409040  
Well #55-806522

### SOURCE WATER PROTECTION AREAS Potential Contaminant Time-of-Travel (in years) to Reach Water Supply



Pinedale Estates DWID  
Well # 55-806522  
Time-of-Travel  
5 years = 315 ft  
10 years = 445 ft  
15 years = 545 ft

● Active Well



This map is for general reference only and may not be all inclusive.  
More detailed information and specific locations can be obtained  
by contacting the Arizona Department of Environmental Quality.

Document Name: SWP PinedaleEstates\_09040.kml

Example: If a pollutant is spilled within the 5 year time-of-travel area,  
it is possible the contaminant may reach the well in 5 years or less.

- The distance for potential contaminants to reach the well are calculated based on the hydro-geological setting and the well characteristics
- If a pollutant is spilled within the 5 year time-of-travel area, it is possible the contaminant may reach the well in 5 years or less



**Pinedale Estates DWID Source Water Protection Plan**

- The Source Water Protection (SWP) Plan does not address selenium
- ADEQ can update the SWP Plan if a new well is installed

Arizona Department of Environmental Quality (ADEQ)'s Source Water Protection (SWP) Program recently completed the SWP Plan for the Pinedale Estates DWID water system. The purpose of the SWP Plan is to protect the community's drinking water from contamination. Any potential source of contamination within one-half mile of your drinking water wells are of the greatest concern since they can most easily become a risk to human health. The following recommendations from the SWP Plan will help ensure that the community's drinking water remains protected for many years to come.

**Recommendations for Neighbors**

Speak with your neighborhood group to:

*Set maintenance schedules for inspecting and pumping septic tanks in the area.*

*Encourage residents to scoop, bag and place pet waste in the trash for proper disposal. If left on the ground, contaminants in pet waste could potentially leach into the groundwater. And, few residential septic systems are designed to handle pet waste.*

*Collect automotive fluids for proper storage and disposal. Automotive fluids should be stored in containers designed for each specific type of fluid. Most automotive fluids can be disposed of at local auto parts stores and household hazardous disposal facilities or events.*

*Encourage use of low-flow plumbing fixtures.*

**Recommendations for local Businesses**

Speak with your local businesses to determine best management practices, which can significantly reduce the risk of contamination source water. This may include:

- Proper chemical storage and waste disposal

**Recommendations for the Water Systems wells**

The well is in a flood zone. Either install a new well outside the flood zone or upgrade the well to ensure it meets minimum ADEQ requirements for wells in the flood zone.

Install security lighting at the well site and conduct regular yard maintenance to control vegetation.

**Work with local authorities to post signs:**

- "This is a Drinking Water Protection Area" at the well site
- "Do Not Dump" signs next to Dobson Creek

**Keep your SWP Plan up to date.**

Update your plan every two to three years to account for land use changes. Review the SWP areas annually for changes in land use and potential sources of contamination.

Additional information and best management practices can be found in the Pinedale Estates DWID Source Water Protection Plan that ADEQ provided to the community.

**Source Water Protection Contact Information**

David Burchard, MBA  
 Hydrologist  
 602-771-4298  
 Burchard.David@azdeq.gov

Victor Scherer, PG  
 Hydrologist IV  
 602-771-4597  
 Scherer.Victor@azdeq.gov

For translations or other communications aids, please email the Title VI Coordinator at [Bingham.Ian@azdeq.gov](mailto:Bingham.Ian@azdeq.gov).

Para traducciones u otras ayudas de comunicación, envíe un correo electrónico al Coordinador del Título VI al [Bingham.Ian@azdeq.gov](mailto:Bingham.Ian@azdeq.gov).



A septic tank should be pumped at a minimum every 3 to 5 years

# Do Your Part. Be SepticSmart!

**septicSMART**  
A U.S. Environmental Protection Agency Program  
[www.epa.gov/septic](http://www.epa.gov/septic)

**Shield Your Field**  
Divert rain and surface water away and avoid parking vehicles and planting trees on your drainfield.

**Don't Overload the Commode**  
Don't flush diapers, wipes or other items meant for a trashcan down the toilet.  
Toilet paper only

**Think at the Sink**  
Limit use of your garbage disposal and avoid pouring fats, grease, solids and harsh chemicals down the drain.

**Don't Strain Your Drain**  
Use water efficiently and stagger use of water-based appliances, such as your washing machine or dishwasher.

**Protect It and Inspect It**  
A typical septic system should be serviced every one to three years by a septic service professional.

**Pump Your Tank**  
Ensure your septic tank is pumped at regular intervals as recommended by a professional.

**Keep It Clean**  
If you are on a well, test your drinking water regularly to ensure it remains clean and free of contamination.

Drainfield  
Septic Tank  
Well  
Groundwater Recharge  
Aquifer

**EPA**  
830-F-180-03 | May 2018

# Status of the Water System

PINEDALE ESTATES  
 DOMESTIC WATER IMPROVEMENT DISTRICT  
 NAVAJO COUNTY, ARIZONA  
 PWS ID #09-040

**SYSTEM EVALUATION &  
 ASSET MANAGEMENT PLAN**

June 2019



Prepared for Arizona Department of Environmental Quality

By:




P.O. Box 10790  
 Glendale, AZ 85318-0790

## Summary of Recommended System Improvements

Item	Improvement
Site Conditions at Water Facility	<ul style="list-style-type: none"> <li>• Improve site conditions:               <ul style="list-style-type: none"> <li>○ Install adequate signage.</li> <li>○ Repair fencing.</li> <li>○ Clear vegetation inside and outside of the facility.</li> <li>○ Remove abandoned metal water storage tank. done</li> </ul> </li> </ul>
Well	<ul style="list-style-type: none"> <li>• Improve well site:               <ul style="list-style-type: none"> <li>○ Install concrete pad.</li> <li>○ Raise well casing above grade-level.</li> </ul> </li> <li>• Address selenium level</li> <li>• Increase production capacity.</li> </ul>
Storage Tank	<ul style="list-style-type: none"> <li>• Immediately. install overflow piping.</li> <li>• Long-term, add additional storage tank(s) or replace the existing poly tanks with a 30,000-gallon tank.</li> </ul>
Booster Pumps	<ul style="list-style-type: none"> <li>• Install second booster pump.</li> <li>• Replace all piping inside the booster pump shed.</li> </ul>
Electrical & Controls	<ul style="list-style-type: none"> <li>• Replace existing motor control systems.</li> <li>• Install auto-dialer to alert operator of alarms.</li> </ul>
Distribution System	<ul style="list-style-type: none"> <li>• Update and digitize piping network map.</li> <li>• Install additional blow-off valves.</li> <li>• Replace transite pipes as required.</li> </ul>

Prioritization and budgetary costs for these improvements are presented in Section 8, under **Asset Management Plan**.

# Selenium Concentrations 1993-present





---

## *Selenium (Se)*

**Naturally occurring in soil & water**  
**MCL = 0.05 mg/L**



**Chronic contaminant**  
**Excess selenium can lead to**



Location, Location, Location . . .


Continued use of this site would require raising wellhead above the 100-year floodplain and protected from inundation




Flood Hazard Zones	
	1% Annual Chance Flood Hazard
	Regulatory Floodway



Private Well  
Sampling

East side of Wash  
 sampled today

Pinedale Estates wellsite



8/9/19 sampling

	Se (mg/L)	gross alpha (pCi/L)	Mn (mg/L)
MCL	0.05	0.015	
SMCL			0.05
A	<0.002	0.007	<0.02
B	<0.002	0.009	<0.02
C	<0.002	0.012	0.092
D	0.015	0.012	<0.02
E	<0.002	0.010	0.062
PE Well	0.38	0.014	0.08

9/25/19 sampling after  
purging water from the well

	Se (mg/L)	Fe (mg/L)	Mn (mg/L)
MCL	0.05		
SMCL		0.3	0.05
C	<0.002	3.7	0.059
E	0.042	2.2	0.026
PE Well	0.42	1.3	0.08

# Options

## Changes Required to Treat at Current Wellsite

- Raise wellhead minimum 3 feet above base flood elevation and install a well seal (6 x 6 foot concrete slab) 2 feet above the flood elevation
- Install 30'x40' treatment building minimum 1 foot above base flood elevation
- Brine disposal – either
  - evaporation pond (offsite) or
  - brine tank and haul (hazardous?)
- Upgrade power from single phase → 3 phase
- Higher grade of operator – currently D1; will need at least T1 or T2
- Cost of treatment

## Drill New Well & Relocate East of Wash

- Determine general location for new well
- Purchase / lease land for well & water system
- Install improvements: fencing, power, signage
- Drill, case & equip well (~\$25-40k)
- Move existing storage tanks & booster pumps to new site
- Extend transmission line from new site to current distribution system – may require easements
- Determine if additional equipment (e.g., pumps) are needed to provide water to all customers




# Summary of Treatment Options

## Reverse Osmosis Treatment

Treatment System - iron/manganese pretreatment, anti-scalant, regeneration system, membrane filter, controls

	<b>\$140,000</b>
Installation Costs	\$90,000
Electrical & Instrumentation Costs	\$60,000
30' X 40' Building to house treatment & controls	\$50,000
Evaporation Pond 0.6 ac x 4' depth – outside of floodplain	\$150,000
Design, legal, administrative, contingency	\$200,000
<b>Capital Cost Estimate for RO Treatment</b>	<b>\$690,000</b>

Annual O&M Costs (power, consumables, chemicals, labor) **\$28,000**




## Ion Exchange Treatment System

Treatment System - (2) 24"x72" vessels, iron/manganese pretreatment, brine pumps, brine makes/tank, controls

	<b>\$150,000</b>
Installation Costs	\$100,000
Electrical & Instrumentation Costs	\$63,000
30' X 40' Building to house treatment & controls	\$50,000
Design, legal, administrative, contingency	\$200,000
<b>Capital Cost Estimate for IX Treatment</b>	<b>\$575,000</b>

Annual O&M Costs (power, consumables, labor) **\$42,000**



# Next Steps

- Consent order
- Decide on best path forward – best option for community
- Pursue funding for design and construction for chosen option
- Funding Options
  - WIFA -- has a design grant up to \$50,000 that is wrapped into construction loan
    - “forgivable principal” amount based on median household income
    - fairly streamlined process – estimate 3-6 months
  - USDA -- has a SEARCH grant up to \$35,000 (25% local match) to develop Preliminary Engineering Report & Environmental Assessment
    - would still need funding for actual design & construction
    - “grant” amount is based on median household income
    - significant paperwork, local office in Show Low – estimate 6-12 months for SEARCH grant
  - ADEQ – technical assistance program could assign a contractor to develop design documents & approval to construct application (design docs, plans, application)
    - would still need funding for construction
  - Combination of the above funding options

## Questions??

### Contacts:

David Burchard, Hydrologist, Source Water Protection  
602.771.4298 [db2@azdeq.gov](mailto:db2@azdeq.gov)

Chelsey McGuire, Technical Assistance Program  
602.771.4324 [cm17@azdeq.gov](mailto:cm17@azdeq.gov)

Linda Taunt, Technical Assistance Program  
602.771.4416 [lc1@azdeq.gov](mailto:lc1@azdeq.gov)